

GBE S.p.A. TEST REPORT

Order

Customer VESTFOLD TRAFO ENERGI AS

Type ER3024.1250

Serial Number20528_1

Phase 3

KVA 1.250

Voltage ratio (V) 22.000-

11.000 +2- 4 X 2,50 % / 415 -

50 Hz

Connection Dyn11

Currents 32,80 - 65,61 / 1.739,01 -

Insulation Class A / A

Temperature Class 65 °C / 65 °C

Measurement of no-load loss and current

| Winding supply : | | | | Secondary | | Measured at | | | 415,0 V | | Frequency | | 50 Hz |
|------------------|--------|--------|--------|---------------|-----------|-------------|--------|--------|---------|---|-----------|--|-------|
| Voltage K = | | | | 1 | Current K | | | 1 | K W = | 1 | Note | | |
| VMuv | VMuw | VMvw | VMm | Iu | IV | Iw | Averag | W tot | | | | | |
| 416,90 | 413,92 | 416,61 | 415,81 | 2,14 | 2,66 | 2,70 | 2,50 | 954,28 | | | | | |
| I0 = 0,14 % | | | | P0 = 954,28 W | | | | | | | | | |

Winding resistance measurement, Voltamperometric method

t. amb. : 20 C°

Note

| Primary winding | | 22.000 V | | Secondary winding | | 415 V | |
|------------------------------|--------|--------------------|--------|------------------------------|---------|-------------|--------|
| Terminals | Volt | Amp. | Ohm | Terminals | mVolt | Amp. | mOhm |
| 1U1V | 9,0553 | 3,6808 | 2,4601 | 2U2V | 11,7439 | 14,9853 | 0,7837 |
| 1U1W | 9,0429 | 3,6964 | 2,4464 | 2U2W | 11,8003 | 14,9852 | 0,7875 |
| 1V1W | 9,0498 | 3,6878 | 2,4540 | 2V2W | 11,7686 | 14,9853 | 0,7853 |
| Average resistance (20,0 C°) | | 2,4535 Ohm | | Average resistance (20,0 C°) | | 0,7855 mOhm | |
| Average resistance | | Average resistance | | | | | |

Measurement of short circuit impedance and load loss

| Winding supply : | | | | Primary | | | A Current | | 32,80 A | | Frequency | 50 Hz |
|------------------|--------|--------|--------|-----------|-------|-------|-----------|----------|---------|------|-----------|-------|
| Voltage K = | | 1 | | Current K | | | 1 | K W = | 1 | Note | | |
| Vuv | Vuw | Vvw | Vm | Iu | lv | Iw | Averag | W tot | | | | |
| 1.288, | 1.281, | 1.289, | 1.286, | 30,31 | 30,37 | 30,34 | 30,34 | 7.623,94 | | | | |

Determination of short circuit impedance and load loss

| Determination of short circuit impedance and load loss | | | | | | |
|---|----------------|--|-----------|-------------------------------|-------------|--|
| Ratio | 22.000 / 415 V | Primary winding | Aluminium | Secondary winding | Aluminium | |
| Ambient temperature | 20,0 °C | Reference temperature | 75 °C | K Temp | 1,22 / 1,22 | |
| Vcc at rated current | 1.390,92 V | RIn % = RIp % * KTemp | 0,87 % | Ohmic losses primary windings | 4.849,4 W | |
| ZIp% = (VCC/VNcc)*100 = | 6,32 % | XIn% = XIp% | 6,28 % | Ohmic losses secondary | 4.363,1 W | |
| RIp % (WCup/PN)*100 | 0,71 % | ZIn % = ((XIn%) ² + (RIn%) ²) = | 6,34 % | Additional losses | 1134,4 W | |
| XIp % = ((ZIp%) ² - (RIP%) ²) ^{1/2} | 6,28 % | Load losses | 10346,8 W | | | |
| Pcc at rated current | 8912,5 W | | | | | |

| Efficiency | | Voltage drop (%) | | |
|------------|------------|------------------|------------|----------|
| load | Cos F =0,8 | Cos F =1 | Cos F =0,8 | Cos F =1 |
| 100 % | 98,883 % | 99,104 % | 4,533 % | 1,024 % |
| 75 % | 99,105 % | 99,283 % | 3,382 % | 0,731 % |
| 50 % | 99,297 % | 99,437 % | 2,243 % | 0,463 % |

Tests carried out according to IEC 60076 Standards.

Instrument used Norma D5255 and Norma 4000.

The transformer is delivered with the following ratio

11.000 / 415 V

Customer

Manufacturer

Date 27/10/2023